


Enterprise Canal



Raw Water
Intake

Flash Mix

Actiflo Basins
(Hydrocyclones)

Ozone Contact Basins

Supernatant Return Water

Settling/Evaporation Basins

Continuous Solids Stream

Equalization
Basin

Backwash Water


Granulated
Activated Carbon
Filters

Treated Water
Reservoir



Chlorination and
pH adjustment

LEEGEND

Process Flow



Wastestreams



To
Distribution System

Backwash Water

PROCESS FLOW DIAGRAM

Order No. R5-2009-____
Waste Discharge Requirements
For
City of Fresno
Surface Water Treatment Plant
Fresno County

ATTACHMENT B